

Performance Reports PERFORMANCE REPORT (2020-21)

Form-1 CONSUMER SERVICE AND SYSTEM PERFORMANCE ANNUAL REPORT 20-2021 Guaranteed Standards-Unplanned Power Supply Interruptions

Consumer Supply Voltage	Total Number of Unplanned Consumer Power Supply Interruptions	Number of Urban Unplanned Consumer Power Supply Interruptions (GSIU)		Unplanned Consumer Power Supply Interruptions		Unplanned S Inte	per of Rural Consumer Power Supply rruptions (GSIR)
		Restored within 10 Hrs	Extending Beyond 10 Hrs	Restored within 16 hrs	Extending Beyond 16 Hrs		
220 KV	0	0	0	0	0		
132 KV	0	0	0	0	0		
66 KV	0	0	0	0	0		
33 KV	0	0	0	0	0		
11 KV	504	504	0	0	0		
400/230 V	34475	34475	0	34475	0		

Consumer Supply Voltage	Maximum- Permitted Number of Unplanned Power Supply Interruptions for Each Individual consumer Per Annum (GS2)	Number of Consumers Whose Number of Unplanned Power Supply Interruptions exceeded the Maximum Limit of GS2	Maximum Permitted Aggregate Duration of Unplanned Power Supply Interruptions for Each Individual Consumer Per Annum (Hours) (GS3)	Number of Consumers Whose Aggregate Unplanned Power Supply Interruption Time exceeded the Maximum Limit of GS3
220 KV	6	0	26	0
132 KV	6	0	26	0
66 KV	6	0	26	0
33 KV	30	0	44	0
11 KV	30	0	44	0
400/230 V Urban	60	98761	88	139
400/230 V Rural	80	11269	175 (distribution Company), 240 for KESC	3262

Form-2
CONSUMER SERVICE AND SYSTEM PERFORMANCE ANNUAL REPORT 20-2021
Guaranteed Standards-Planned Power Supply Interruptions

Consumer Supply Voltage	Maximum Permitted Number of Planned Power Supply Interruptions for Each Individual Consumer Per Annum (GS4)	Number of Consumers Whose Planned Power Supply Interruptions exceeded the Maximum Limit of GS4	Maximum Power Supply Interruption Aggregate Duration (Hours) for each Individual Consumer Per Annum (GS5)	Number of Consumers Whose Aggregate Planned Power Supply Interruption Duration Exceeded the maximum Limit of (GS5)
220 KV	4	0	36	0
132 KV	4	0	36	0
66 KV	4	0	36	0
33 KV	8	0	64	0
11 KV	8	10	64	0
400/230 V Urban	16	46719	80	0
400/230 V Rural	16	19102	96	0

Form-3
CONSUMER SERVICE AND SYSTEM PERFORMANCE ANNUAL REPORT 20-2021
Guaranteed Standards-Unplanned Short Duration Power Supply Interruptions

Consumer Supply Voltage	Maximum Permitted Number of Short Duration Power Supply Interruptions for Each Individual Consumer Per Annum (GS6)	Number of Consumers Whose Short Duration Power Supply Interruptions Exceeded the Maximum Limit of (GS6)
132/66 KV	4	0
33/11 KV	140	0
400/230 V Urban	275	0
400/230 V Rural	300	0

Form-4
CONSUMER SERVICE AND SYSTEM PERFORMANCE ANNUAL REPORT 20-2021
Overall Standards- Average Power Supply Interruptions*

Consumer Supply	Total Number of Consumers Served	Total Annual Number of Consumer Power Supply	SAIFI	Aggregate Sum of All Consumer Power	SAIDI
Voltage	by the Distribution Company in a Given Year	Interruptions **	(OSI) (4)=(3)/(2)	Supply Interruption Duration in Minutes ***	(OS2) (6)=(5)/(2)
1	2	3	4	5	6
220 KV	0	0	0	0	0
132 KV	0	0	0	0	0
66 KV	0	0	0	0	0
33 KV	0	0	0	0	0
11 KV	81	1945	24.01	162375	2004.63
400/230 V	640449	62749494	97.98	5236992459	8177.06

Form-5 CONSUMER SERVICE AND SYSTEM PERFORMANCE ANNUAL REPORT 20-2021

				Sheet 5
			Total Number of eligible	Total Number of
Eligible	Maxim * time	Total Number	consumers	eligible consumers
Eligible Consumer's New	Period for	of eligible	who applied for a	who applied for a
Power Supply Connection	Provision of New	Consumers who	new connection and	new connection but
Requirements (Voltage and	Connection	Applied for a	were connected within	did not receive
Load Level Specific)	(Calendar Days)	New Connection	the maximum permitted	connection within the
	(OS3)		time period of OS3	maximum permitted time period of OS3
Voltage Level up to 400 V and Load up to 15 KW (Urban)	30	22302	16042	6260
Voltage Level up to 400 V and Load up to 15 KW (Rural)	30	3783	1864	1919
Voltage Level up to 400 V and Load above 15 KW but not exceeding 70 KW	53	148	241	59
Voltage Level up to 400 V and Load Above 70 KW but no exceeding 500 KW	73	24	24	0
Voltage Level 11 KV or 33 KV and Load above 500 KW but not exceeding 5000 KW	106	0	0	0
Voltage Level 66 KV and above for all loads	496	-	-	-

Form-6
CONSUMER SERVICE AND SYSTEM PERFORMANCE ANNUAL REPORT 20-2021
Overall Standards - Nominal Voltages

Sheet 6

Consumers Supply	Maximum	Number of Consumers who	Number of Times where a
Voltage	Permitted Voltage	requested their Power Supply	Remedial Action followed a
(OS4)	Level Deviations	Voltage Levels to be checked	consumer request about his Power supply voltage level check
220 KV (If applicable)	+/-5%	-	-
132 KV	+/-5%	-	-
66 KV	+/-5%	-	-
33 KV	+/-5%	-	-
11 KV	+/-5%	7	7
400/230 V Urban	+/-5%	1961	1935
400/230 V Rural	+/-5%	1305	897

Note: Detailed Breakup of the complaints is at **Annex "B"**

Form-7 CONSUMER SERVICE AND SYSTEM PERFORMANCE ANNUAL REPORT 20-2021 Overall Standards – Frequency

Consumer Frequency	Maximum Permitted Frequency Deviations	Total Number of Consumers who requested their Frequency levels to be checked	Total Number of times where a remedial action followed a consumer request about his frequency level check
50 Hertz	±1%	NIL	NIL

Form-8 CONSUMER SERVICE AND SYSTEM PERFORMANCE ANNUAL REPORT 20-2021 Overall Standards - Load Shedding

Priority Group of Consumers	Number of Instances of Actuation of Load shedding (OS6)	Average Duration of Load Shedding Period (Hours)	Maximum Duration of Load Shedding Period (Hours)	Number of Consumers Affected in Each Priority Group	Load (MW) Interrupted Due to Load Shedding in Each Priority Group	
Consumers in Rural Areas, and Residential Consumers in Urban Areas	1. Urban/ Rural QTA & its suburbs 3 times/ day. 2. Urban/ Rural outside QTA 1- Times/day.	1. Avg: 6-8 hrs/ day 2. Avg: 12-16 hrs/ day	1. Avg 2555 hrs/ year 2. Avg 5110 hrs/year	1. 1,42,415 2. 1,49,674	1. Urban = 130-140 MW 2. U/R outside QTA= 600 - 650 MW	
Consumers other than Industrial in Urban Areas	3 times / day	Avg 6 - 8 hrs	2555 hrs/ year	1,39,272	100-120	
Agricultural Consumers where there is dedicated Supply	-	-	-	-	-	
Industrial Consumers.	NIL					
Supply to Schools and Hospitals	NOTE: All Schools & Hospitals are on General Feeders except BMC, CMH & Kidney center etc					
Defense/Strat egic Installation		ding of Defense/ St norities themselves.		ons is being ca	rried out by the	

Form-9 CONSUMER SERVICE AND SYSTEM PERFORMANCE ANNUAL REPORT 20-2021 Overall Standards - Safety

Sheet 9

Type of Incident	Number of Electrical Incidents	Average Duration of absence from Work	Longest Duration of absence from Work
Electrical Incident resulting in death / Permanent Serious Injury/Disability to	03	Fatal	Fatal
Member of Staff.	02	133 days	261 days
Electrical Incident resulting in Injury to Member of Staff requiring Hospital treatment or absence from work for five days or more.	05	60 days	261 days
Electrical incident resulting in Injury to Member of Staff requiring absence from work for 105 days.	0	-	-
Electrical incident resulting in Injury to Member of staff nor requiring absence from work.	01	-	-
Electrical incident resulting in death or permanent serious injury/disability to member of the public.	03	-	-
Electrical Incident Injuring member of the public involving Distribution Company's Plant or equipment.	01	-	-
Electrical incident injuring member of the public nor involving Distribution Company's plant or equipment	-	-	-
Safety reports received on toll free telephone number	-	-	-

Each electrical incident shall be individually reported on an immediate basis giving the following information:

Time and date of electrical incident, FIR lodged or not, names and occupation of persons involved, number of

fatalities, extent of injuries, names and contact details of witnesses, distribution company's inquiry held or not, Immediate action taken, and remedial actions proposed and /or taken or to be taken (Annex-C)

Form-10

CONSUMER SERVICE AND SYSTEM PERFORMANCE ANNUAL REPORT 20-2021

Consumer Formal Complaints Report


Nature of Complaint	Received in Person	Received by Telephone	Received Electronically	Received in Writing	Average Time in hours to resolve a Complaint	Longest Time in hours to Resolve a Complaint
Price of					_	-
Electricity	-	0	-	-	-	-
Reliability of						
Supply	-	2451	1255	-	1:45	4:25
Planned						
Interruptions	-	2623	-	-	5:00	8:00
Supply Voltage						
Level	-	3197	69	-	1:30	2:30
New Connection	-	0	-	-	-	-
Safety	-	51	23	13	3:00	8:00
Other	-	27145	-	-	2:45	4:45


{ See Rule 7(3) (b)}

Form-11 CONSUMER SERVICE AND SYSTEM PERFORMANCE ANNUAL REPORT 20-2021 System Performance


System Voltage in Service (KV)	Total Length of Distribution System in Service (KM)	Total Number of Distribution System Faults	Faults/KM of Distribution System
220 KV (If Applicable)	_	_	_
132 KV	5499.87	290	0.053
66 KV	106.13	24	0.22
33 KV	1981	712	0.36
11 KV	40821.92	35312	0.865
400/230 V	17476.15	38694	2.214

Graphical Comparison - SAIFI & SAIDI






Graphical Comparison of Last Years (%) of Consumers who were not given Connections within Time Limit




NOTE: Reason for Delay in energization of connections were due to the outbreak of Pandemic (COVID-19).

Graphical Comparison of Last Years Total Complaints Received by QESCO



Graphical Comparison of Last Years Average Load Shedding Duration (Hrs)



Graphical Comparison of Last Years Fatal Accidents

