



LOT # 2 (C) PASNI

**LEGENDS**

1. BITUMINOUS ROAD 3000mm WIDE
2. BITUMINOUS ROAD 4500MM WIDE
3. TRANSFORMER WAY
4. MAIN GATE
5. SWITCHYARD GATE
6. BOUNDARY WALL
7. SWITCHYARD FENCE
8. CONTROL HOUSE BUILDING
9. SEWERAGE MANHOLE
10. SEPTIC TANK
11. OVERHEAD WATER TANK 5000 GALLONS
12. SECURITY GUARD CABIN
13. PUMP HOUSE

PROPOSED: SHOWN AS DOTTED.

**REFERENCE DRAWINGS**

1. SINGLE LINE DIAGRAM DWG. NO SL-008
2. SWITCH YARD LAYOUT DWG. NO. SW-008
3. FOUNDATION LAYOUT DWG. NO. SW-008
4. FOR OTHER DRAWINGS REFER TO WAPDA GLO DWG NO PDW/TS-4011 DT 20-03-06.

**NOTE:**

1. ALL MEASUREMENTS ARE IN MM.
2. PREPARED FROM WAPDA GLO DRAWING NO. PDW/TS -4011 DATED 20-03-06.

|    |            |   |         |
|----|------------|---|---------|
| 1. | 17-01-2020 | ADDED 1 NO. 132kV LINE BAY FOR GWADAR OLD G/S. CONVERSION OF 1 NO ISO BAY INTO 132kV LINE BAY FOR TURBAT AND 132kV BUS TO TWIN BUNDLE CONDUCTOR. EXTENDED SWITCHYARD BUILDING FOR 2 NO. 132kV BAYS. | EnMasse |
|----|------------|---|---------|

| NO. | DATE | REVISION | BY |
|-----|------|----------|----|
|-----|------|----------|----|

CLIENT:- **QESCO**

CONSULTANT :- **EnMasse**

EXISTING: 3 NO. 132kV LINE BAYS, 1 NO. 132kV ISO BAY , 1 NO.10/13MVA, 132/11.5kV T/F BAY.

|          |     |   |
|----------|-----|---|
| NAME     | SIG | TITLE :-  |
| PREPARED | MM  | <b>132 kV PASNI<br/>GRID SUB-STATION<br/>GENERAL LAYOUT</b> |
| CHECKED  | HA  |   |
| APPROVED | CAL |   |

SCALE:- N T S      DRAWING NO. GL-0008      DATE: